

General Information
PWSID ME 0090410
GREAT SALT BAY SANITARY DIST
2015 Consumer Confidence Report

Water System Contact Name: Scott Abbotoni

Address: P.O. Box 23

Damariscotta, Maine, 04543

Telephone #: 207-563-3010

Fax#: 207-563-3262

Email: water@gsbsd.org

Report Covering Calendar Year: Jan 1 - Dec 31, 2015

Upcoming Regularly Scheduled Meeting(s): Second Wednesday of each Month

Source Water Information

Description of Water Source: Surface Water Intakes: 1 (Little Pond)

Water Treatment & Filtration Information: UV Disinfection combined with chlorine and chloramines

Source Water Assessment:

The sources of drinking water include rivers, lakes, ponds, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive material and can pick up substances resulting from human or animal activity. The Maine Drinking Water Program (DWP) has evaluated all public water supplies as part of the Source Water Assessment Program (SWAP). The assessments included geology, hydrology, land uses, water testing information, and the extent of land ownership or protection by local ordinance to see how likely our drinking water source is to being contaminated by human activities in the future. Assessment results are available at town offices, public water suppliers, and the DWP. For more information about the SWAP, please contact the DWP at telephone 287-2070.

Water Test Results

<i>Contaminant</i>	<i>Date</i>	<i>Results</i>	<i>MCL</i>	<i>MCLG</i>	<i>Source</i>
Microbiological					
COLIFORM (TCR) (1)	Jun 2015	1 pos	1 pos/mo or 5%	0 pos	Naturally present in the environment.
Inorganics					
BARIIUM	3/9/2015	0.002 ppm	2 ppm	2 ppm	Discharge of drilling wastes. Discharge from metal refineries. Erosion of natural deposits.
FLUORIDE (2)	12/17/2015	1.1 ppm	4 ppm	4 ppm	Erosion of natural deposits. Water additive which promotes strong teeth. Discharge from fertilizer and aluminum factories.
NITRITE (4)	7/19/2011	0.02 ppm	1 ppm	1 ppm	Runoff from fertilizer use. Leaching from septic tanks, sewage. Erosion of natural deposits.
Radionuclides					
RADIUM-226	6/1/2015	0.23 pCi/l	5 pCi/l	0 pCi/l	Erosion of natural deposits.
Lead/Copper					
COPPER 90TH% VALUE (3)	1/1/2013 - 12/31/2013	0.058 ppm	AL = 1.3 ppm	1.3 ppm	Corrosion of household plumbing systems.
LEAD 90TH% VALUE (3)	1/1/2013 - 12/31/2013	7.8 ppb	AL = 15 ppb	0 ppb	Corrosion of household plumbing systems.

Disinfectants and Disinfection Byproducts

DISTRIBUTION SYSTEM

Health Information

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production and can also come from gas stations, urban runoff, and septic systems.

Radioactive Contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing.

Great Salt Bay Sanitary District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at:

<http://www.epa.gov/safewater/lead>

Violations: None

Waiver Information

In 2014, our system was granted a 'Synthetic Organics Waiver.' This is a three-year exemption from the monitoring/reporting requirements for the following industrial chemical(s): TOXAPHENE/CHLORDANE/PCB, HERBICIDES, CARBAMATE PESTICIDES, SEMIVOLATILE ORGANICS. This waiver was granted due to the absence of these potential sources of contamination within a half mile radius of the water source.

PUFFIN STOP

TOTAL HALOACETIC ACIDS (HAA5) (7)	LRAA(2015)	38 ppb Range (15.2–68 ppb)	60 ppb	0 ppb	By-product of drinking water chlorination.
TOTAL TRIHALOMETHANE (TTHM) (7)	LRAA(2015)	40 ppb Range (13.9–62.4 ppb)	80 ppb	0 ppb	By-product of drinking water chlorination.

Chlorine Residual (Add chlorine residual information)

CHLORINE RESIDUAL	RAA	.77__ ppm	MRDL=4 ppm	MRDLG=	By-product of drinking water chlorination.
		Range (.34 __ - 1.51 ppm)		4 pp	

Turbidity (Add turbidity information, highest monthly reading in 2015)

TURBIDITY		Sep 9-11	.90	NTU	5 ntu	N/A	Soil runoff.
-----------	--	----------	-----	-----	-------	-----	--------------

Definitions:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health.

Running Annual Average (RAA): A 12 month rolling average of all monthly or quarterly samples at all locations. Calculation of the RAA may contain data from the previous year.

Locational Running Annual Average (LRAA): A 12 month rolling average of all monthly or quarterly samples at specific sampling locations. Calculation of the RAA may contain data from the previous year.

Action Level (AL): The concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health.

MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Units:

ppm = parts per million or milligrams per liter (mg/L).

pCi/L = picocuries per liter (a measure of radioactivity).

ppb = parts per billion or micrograms per liter (µg/L).

pos = positive samples.

MFL = million fibers per liter

Notes:

1) Total Coliform Bacteria: Reported as the highest monthly number of positive samples, for water systems that take less than 40 samples per month.

2) Fluoride: For those systems that fluoridate, fluoride levels must be maintained between 0.5 to 1.2 ppm. The optimum level is 0.7 ppm.

3) Lead/Copper: Action levels (AL) are measured at consumer's tap. 90% of the tests must be equal to or below the action level.

4) Nitrate: Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health provider.

5) Gross Alpha: Action level over 5 pCi/L requires testing for Radium 226 and 228. Action level over 15 pCi/L requires testing for Uranium. Compliance is based on Gross Alpha results minus Uranium results = Net Gross Alpha.

6) Radon: The State of Maine adopted a Maximum Exposure Guideline (MEG) for Radon in drinking water at 4000 pCi/L, effective 1/1/07. If Radon exceeds the MEG in water, treatment is recommended. It is also advisable to test indoor air for Radon.

7) TTHM/HAA5: Total Trihalomethanes and Haloacetic Acids (TTHM and HAA5) are formed as a by-product of drinking water chlorination. This chemical reaction occurs when chlorine combines with naturally occurring organic matter in water. Compliance is based on running annual average.

All other regulated drinking water contaminants were below detection levels.

Secondary Contaminants (You are not required to list detects for secondary contaminants, but this information, particularly sodium levels, might be useful to your customers. The decision to supply this information in your CCR is up to you.)

SULFATE	3 ppm	3/9/2015
MAGNESIUM	0.74 ppm	3/9/2015
MANGANESE	0.042 ppm	3/9/2015
SODIUM	14 ppm	3/9/2015
CHLORIDE	13 ppm	3/9/2015
IRON	0.1 ppm	3/9/2015
NICKEL	0.0011 ppm	3/9/2015
ZINC	0.002 ppm	3/19/2012

Certification

I Scott Abbotoni hereby certify and attest that I have distributed copies of this Consumer Confidence

Report to all users of my public water system on 5/22/16, by mail , posted in the newspaper , or electronically , in accordance with 40 CFR§141-142. I further certify that the information contained in this annual Consumer Confidence Report is correct and consistent with compliance monitoring data. Any intentional deception or misinformation represented in this report may be cited as a violation of State and U.S. EPA National Primary Drinking Water Rules.

Signed: 

Dated: 5/22/16