

PWSID ME0090410
GREAT SALT BAY SANITARY DIST
2017 Consumer Confidence Report

General Information

Water System Contact Name: Great Salt Bay Sanitary District

Address: P.O.Box 23

City, State, Zip Code: Damariscotta, Maine 04543

Telephone #: 207-563-5105 Fax#: 207-563-3262 Email: water@gsbsd.org

Report Covering Calendar Year: Jan 1 - Dec 31, 2017

Upcoming Regularly Scheduled Meeting(s): Second Wednesday of each Month

Source Water Information

Description of Water Source: Surface Water Intakes: 1 (Little Pond)

Water Treatment & Filtration Information:

UV Disinfection combined with chlorine and chloramines

Source Water Assessment:

The sources of drinking water include rivers, lakes, ponds, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive material and can pick up substances resulting from human or animal activity. The Maine Drinking Water Program (DWP) has evaluated all public water supplies as part of the Source Water Assessment Program (SWAP). The assessments included geology, hydrology, land uses, water testing information, and the extent of land ownership or protection by local ordinance to see how likely our drinking water source is to being contaminated by human activities in the future. Assessment results are available at town offices and public water systems.

Definitions:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health.

Running Annual Average (RAA): A 12 month rolling average of all monthly or quarterly samples at all locations. Calculation of the RAA may contain data from the previous year.

Locational Running Annual Average (LRAA): A 12 month rolling average of all monthly or quarterly samples at specific sampling locations. Calculation of the RAA may contain data from the previous year.

Action Level (AL): The concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Units:

ppm = parts per million or milligrams per liter (mg/L).

ppb = parts per billion or micrograms per liter (µg/L).

pCi/L = picocuries per liter (a measure of radioactivity).

pos = positive samples.

MFL = million fibers per liter

Water Test Results

Contaminant	Date	Results	MCL	MCLG	Possible Sources of Contamination
-------------	------	---------	-----	------	-----------------------------------

Microbiological

COLIFORM (TCR) (1)	Oct 2017	1 pos	1 pos/mo or 5%	0 pos	Naturally present in the environment.
--------------------	----------	-------	----------------	-------	---------------------------------------

Inorganics

BARIUM	4/18/2017	0.0019 ppm	2 ppm	2 ppm	Discharge of drilling wastes. Discharge from metal refineries. Erosion of natural deposits.
FLUORIDE (3)	3/8/2017	0.86 ppm	4 ppm	4 ppm	Erosion of natural deposits. Water additive which promotes strong teeth. Discharge from fertilizer and aluminum factories.

Volatile Organics

TOLUENE	12/18/2017	0.0013 ppm	1 ppm	1 ppm	Discharge from petroleum factories.
---------	------------	------------	-------	-------	-------------------------------------

Radionuclides

RADIUM-226	6/1/2015	0.23 pCi/l	5 pCi/l	0 pCi/l	Erosion of natural deposits.
------------	----------	------------	---------	---------	------------------------------

Lead/Copper

COPPER 90TH% VALUE (4)	1/1/2014 - 12/31/2016	0.044 ppm	AL = 1.3 ppm	1.3 ppm	Corrosion of household plumbing systems.
LEAD 90TH% VALUE (4)	1/1/2014 - 12/31/2016	7.2 ppb	AL = 15 ppb	0 ppb	Corrosion of household plumbing systems.

Disinfectants and Disinfection Byproducts

PUFFIN STOP

TOTAL HALOACETIC ACIDS (HAA5) (9)	LRAA(2017)	26 ppb Range (13.2-25 ppb)	60 ppb	0 ppb	By-product of drinking water chlorination.
TOTAL TRIHALOMETHANE (TTHM) (9)	LRAA(2017)	45 ppb Range (28.7-52.9 ppb)	80 ppb	0 ppb	By-product of drinking water chlorination.

Chlorine Residual (Add chlorine residual information)

CHLORINE RESIDUAL	Range (.27 - 1.98 ppm)	MRDL=4 ppm	MRDLG=4 ppm	By-product of drinking water chlorination.
-------------------	------------------------	------------	-------------	--

Turbidity (Add turbidity information, highest monthly reading in 2017)

TURBIDITY	July 27	.98 NTU	5 ntu	N/A	Soil runoff.
-----------	---------	---------	-------	-----	--------------

Notes:

- 1) Total Coliform Bacteria: Reported as the highest monthly number of positive samples, for water systems that take less than 40 samples per month.
- 2) E. Coli: E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Human pathogens in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a greater health risk for infants, young children, the elderly, and people with severely-compromised immune systems.
- 3) Fluoride: For those systems that fluoridate, fluoride levels must be maintained between 0.5 to 1.2 ppm. The optimum level is 0.7 ppm.
- 4) Lead/Copper: Action levels (AL) are measured at consumer's tap. 90% of the tests must be equal to or below the action level.
- 5) Nitrate: Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health provider.
- 6) Arsenic: While your drinking water may meet EPA's standard for Arsenic, if it contains between 5 to 10 ppb you should know that the standard balances the current understanding of arsenic's possible health effects against the costs of removing it from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems. Quarterly compliance is based on running annual average.
- 7) Gross Alpha: Action level over 5 pCi/L requires testing for Radium 226 and 228. Action level over 15 pCi/L requires testing for Uranium. Compliance is based on Gross Alpha results minus Uranium results = Net Gross Alpha.
- 8) Radon: The State of Maine adopted a Maximum Exposure Guideline (MEG) for Radon in drinking water at 4000 pCi/L, effective 1/1/07. If Radon exceeds the MEG in water, treatment is recommended. It is also advisable to test indoor air for Radon.
- 9) TTHM/HAA5: Total Trihalomethanes and Haloacetic Acids (TTHM and HAA5) are formed as a by-product of drinking water chlorination. This chemical reaction occurs when chlorine combines with naturally occurring organic matter in water. Compliance is based on running annual average.

All other regulated drinking water contaminants were below detection levels.

Secondary Contaminants (You are not required to list detects for secondary contaminants, but this information, particularly sodium levels, might be useful to your customers. The decision to supply this information in your CCR is up to you.)

IRON	0.096 ppm	4/18/2017
------	-----------	-----------

SULFATE	3 ppm	4/18/2017
SODIUM	16 ppm	4/18/2017
ZINC	0.0011 ppm	4/18/2017
CHLORIDE	12 ppm	4/18/2017
MANGANESE	0.031 ppm	4/18/2017
MAGNESIUM	0.92 ppm	4/18/2017
NICKEL	0.0011 ppm	3/9/2015

Health Information

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production and can also come from gas stations, urban runoff, and septic systems.

Radioactive Contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791) or at the following link:

<https://www.epa.gov/ccr/forms/contact-us-about-consumer-confidence-reports>

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Great Salt Bay Sanitary Dist is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested.

Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at the following link:

<http://www.epa.gov/safewater/lead>

Violations

No Violations in 2017

Waiver Information (to be included in the CCR for systems that were granted a waiver)

In 2017, our system was granted a 'Synthetic Organics Waiver.' This is a three year exemption from the monitoring/reporting requirements for the following industrial chemical(s): TOXAPHENE/CHLORDANE/PCB, HERBICIDES, CARBAMATE PESTICIDES, SEMIVOLATILE ORGANICS. This waiver was granted due to the absence of these potential sources of contamination within a half mile radius of the water source(s).

Maine Drinking Water Program Consumer Confidence Report Certification Form

PWSID#: ME0090410

Name of Public Water System: GREAT SALT BAY SANITARY DIST

Instructions:

1. Distribute copies of your Consumer Confidence Report (CCR) to all users served by your public water system by **JULY 1ST**.
2. Please complete the certification below and submit with a copy of the Consumer Confidence Report distributed to customers to the Maine Drinking Water Program by **OCTOBER 1ST**.


Date distribution completed: _____ Check all applicable distribution methods:

✓	Direct Delivery Method to each customer	✓	Good Faith Effort to reach non-bill paying or other consumers
	Mail paper copy		Mailing the CCR to postal patrons within the service area (attach zip codes used).
	Hand Deliver		Delivery of multiple copies to single bill addresses serving several persons such as: apartments, businesses, and large private employers. <i>Please list.</i>
	Mail notice that CCR is available on website via a direct URL www. _____		Posting on Internet at URL www. _____
	Email direct URL		Posting the CCR in public places (<i>attach a list of locations</i>).
	Email CCR as a file attachment		Publication of CCR in local newspaper (<i>attach copy</i>).
	Email CCR in message		Advertising availability of the CCR in news media (<i>attach copy of announcement</i>).
	Publication of CCR in local newspaper (<i>attach copy</i>). Approval needed.		Delivery to community organizations (<i>attach a list</i>).
	Availability of paper copy (systems less than 500 persons)		Availability of paper copy
If other than hand delivery or mailing describe how customers were notified and send an example.			

Certification of Distribution and Accuracy of Consumer Confidence Report

I certify that the information in the attached/enclosed CCR contains all data and required language found in the Fillable CCR provided by the Drinking Water Program and that the CCR was distributed by July 1st by the methods noted above.

Name of licensed designated operator: Scott L Abbotoni
Please print

Signature:  Date: 3/27/18

**Email CCR form and attachments to your Public Water System Inspector or mail to:
Maine Drinking Water Program, 11 State House Station, Augusta, ME 04333-0011**