

PWSID ME0090410
GREAT SALT BAY SANITARY DISTRICT
2020 Consumer Confidence Report

General Information

Water System Contact Name: Great Salt Bay Sanitary District

Address: P.O. Box 23

City, State, Zip Code: Damariscotta, Maine 04543

Telephone #: 207-563-5105

Fax#: 207-563-3262

Email: scottabbotoni@gsbsd.org

Report Covering Calendar Year: Jan 1 - Dec 31, 2020

Upcoming Regularly Scheduled Meeting(s): second wednesday of each month

Source Water Information

Description of Water Source: Surface Water Intakes: 1 (Little Pond)

Water Treatment & Filtration Information:

U.V. Disinfection combined with chlorine and chloramines

Source Water Assessment:

The sources of drinking water include rivers, lakes, ponds, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive material and can pick up substances resulting from human or animal activity. The Maine Drinking Water Program (DWP) has evaluated all public water supplies as part of the Source Water Assessment Program (SWAP). The assessments included geology, hydrology, land uses, water testing information, and the extent of land ownership or protection by local ordinance to see how likely our drinking water source is to being contaminated by human activities in the future. Assessment results are available at town offices and public water systems.

Definitions:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health.

Running Annual Average (RAA): A 12 month rolling average of all monthly or quarterly samples at all locations. Calculation of the RAA may contain data from the previous year.

Locational Running Annual Average (LRAA): A 12 month rolling average of all monthly or quarterly samples at specific sampling locations. Calculation of the RAA may contain data from the previous year.

Action Level (AL): The concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Units:

ppm = parts per million or milligrams per liter (mg/L).

pCi/L = picocuries per liter (a measure of radioactivity).

ppb = parts per billion or micrograms per liter (µg/L).

pos = positive samples.

MFL = million fibers per liter

SODIUM	12 ppm	5/19/2020
ZINC	0.0011 ppm	5/19/2020

Health Information

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production and can also come from gas stations, urban runoff, and septic systems.

Radioactive Contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791) or at the following link:

<https://www.epa.gov/ccr/forms/contact-us-about-consumer-confidence-reports>

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Great Salt Bay Sanitary District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at the following link:

<http://www.epa.gov/safewater/lead>

Violations

Violation Period	Violation Type
------------------	----------------

7/1/2020 - 12/31/2020	SE Violation - STATE EXCEEDANCE LEAD SUMMARY
-----------------------	--

Lead & Copper Action Level Exceedance: In 2020, routine sampling detected (lead/copper) in excess of the maximum level allowed. 5 out of 45 sites sampled, exceeded the action level for (lead/copper). Drinking water regulations require that samples are taken from homes with a high risk potential for lead/copper in the plumbing. The following were action steps we were required to take and the dates those actions were completed: Distribute public lead/copper education material to all residents (Done on 4/21); Submit a corrosion control plan to the State Drinking Water Program (Done on 1/3/20). Our plan we submitted to reduce the corrosivity of the water (or reduce lead/copper levels) involves: Adding sodium silicate and soda ash to increase the PH. We have to fully implement/complete our plan by April of 21. Lead/copper sampling will resume in April of 2021. Results of subsequent future lead/copper testing will be made available to all residents. Lead Health Effects: Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure. Copper Health Effects: Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short time could experience gastrointestinal distress, or suffer liver or kidney damage. People with Wilson's Disease should consult their doctor.