

PWSID ME0090410
GREAT SALT BAY SANITARY DISTRICT
2021 Consumer Confidence Report

General Information

Water System Contact Name: Scott Abbotoni
Address: P.O. Box 23
City, State, Zip Code: Damariscotta, Maine 04543
Telephone #: 563-5105 **Fax#:** 563-3262 **Email:** scottabbotoni@gsbsd.org

Report Covering Calendar Year: Jan 1 - Dec 31, 2021

Upcoming Regularly Scheduled Meeting(s): Second Wednesday of each month

Source Water Information

Description of Water Source: Surface Water Intakes: 1 (Little Pond)

Little Pond in Damariscotta is the source of the Drinking water for the area's owns 99.5 % of the surrounding property which helps control water quality

Water Treatment & Filtration Information:

UV treatment combined with chlorine and chloramines

Source Water Assessment:

The sources of drinking water include rivers, lakes, ponds, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive material and can pick up substances resulting from human or animal activity. The Maine Drinking Water Program (DWP) has evaluated all public water supplies as part of the Source Water Assessment Program (SWAP). The assessments included geology, hydrology, land uses, water testing information, and the extent of land ownership or protection by local ordinance to see how likely our drinking water source is to being contaminated by human activities in the future. Assessment results are available at town offices and public water systems.

Definitions:

- Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water.
- Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health.
- Running Annual Average (RAA): A 12 month rolling average of all monthly or quarterly samples at all locations. Calculation of the RAA may contain data from the previous year.
- Locational Running Annual Average (LRAA): A 12 month rolling average of all monthly or quarterly samples at specific sampling locations. Calculation of the RAA may contain data from the previous year.
- Action Level (AL): The concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.
- Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Units:

ppm = parts per million or milligrams per liter (mg/L). pCi/L = picocuries per liter (a measure of radioactivity).
ppb = parts per billion or micrograms per liter (µg/L). pos = positive samples. MFL = million fibers per liter

Water Test Results

| Contaminant | Date | Results | MCL | MCLG | Possible Sources of Contamination |
|-------------|------|---------|-----|------|-----------------------------------|
|-------------|------|---------|-----|------|-----------------------------------|

Microbiological

| | | | | | |
|--------------------|------|-------|----------------|-------|---------------------------------------|
| COLIFORM (TCR) (1) | 2021 | 0 pos | 1 pos/mo or 5% | 0 pos | Naturally present in the environment. |
|--------------------|------|-------|----------------|-------|---------------------------------------|

Inorganics

| | | | | | |
|--------------|-----------|------------|-------|-------|--|
| BARIUM | 5/10/2021 | 0.0024 ppm | 2 ppm | 2 ppm | Discharge of drilling wastes. Discharge from metal refineries. Erosion of natural deposits. |
| FLUORIDE (3) | 8/2/2021 | 1.1 ppm | 4 ppm | 4 ppm | Erosion of natural deposits. Water additive which promotes strong teeth. Discharge from fertilizer and aluminum factories. |

Lead/Copper

| | | | | | |
|------------------------|-----------------------|-----------|--------------|---------|--|
| COPPER 90TH% VALUE (4) | 7/1/2021 - 12/31/2021 | 0.085 ppm | AL = 1.3 ppm | 1.3 ppm | Corrosion of household plumbing systems. |
| LEAD 90TH% VALUE (4) | 7/1/2021 - 12/31/2021 | 21 ppb | AL = 15 ppb | 0 ppb | Corrosion of household plumbing systems. |

Disinfectants and Disinfection Byproducts

PUFFIN STOP

| | | | | | |
|-----------------------------------|-------------|-----------------------------------|--------|-------|--|
| TOTAL HALOACETIC ACIDS (HAA5) (9) | LRAA (2021) | 28.8 ppb Range (24-38 ppb) | 60 ppb | 0 ppb | By-product of drinking water chlorination. |
| TOTAL TRIHALOMETHANE (TTHM) (9) | LRAA (2021) | 45.1 ppb Range (36.7-53.9 ppb) | 80 ppb | 0 ppb | By-product of drinking water chlorination. |

Chlorine Residual (Add chlorine residual information)

| | | | | |
|-------------------|--------------------|------------|-------------|--|
| CHLORINE RESIDUAL | Range (48-235 ppm) | MRDL=4 ppm | MRDLG=4 ppm | By-product of drinking water chlorination. |
|-------------------|--------------------|------------|-------------|--|

Turbidity (Add turbidity information, highest monthly reading in 2021)

| | | | | | |
|-----------|-----------|---------|-------|-----|--------------|
| TURBIDITY | August 25 | .98 NTU | 5 ntu | N/A | Soil runoff. |
|-----------|-----------|---------|-------|-----|--------------|

Notes:

- 1) Total Coliform Bacteria: Reported as the highest monthly number of positive samples, for water systems that take less than 40 samples per month.
- 2) E. Coli: E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Human pathogens in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a greater health risk for infants, young children, the elderly, and people with severely-compromised immune systems.
- 3) Fluoride: For those systems that fluoridate, fluoride levels must be maintained between 0.5 to 1.2 ppm. The optimum level is 0.7 ppm.
- 4) Lead/Copper: Action levels (AL) are measured at consumer's tap. 90% of the tests must be equal to or below the action level.
- 5) Nitrate: Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health provider.
- 6) Arsenic: While your drinking water may meet EPA's standard for Arsenic, if it contains between 5 to 10 ppb you should know that the standard balances the current understanding of arsenic's possible health effects against the costs of removing it from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulator problems. Quarterly compliance is based on running annual average.
- 7) Gross Alpha: Action level over 5 pCi/L requires testing for Radium 226 and 228. Action level over 15 pCi/L requires testing for Uranium. Compliance is based on Gross Alpha results minus Uranium results = Net Gross Alpha.
- 8) Radon: The State of Maine adopted a Maximum Exposure Guideline (MEG) for Radon in drinking water at 4000 pCi/L, effective 1/1/07. If Radon exceeds the MEG in water, treatment is recommended. It is also advisable to test indoor air for Radon.
- 9) TTHM/HAA5: Total Trihalomethanes and Haloacetic Acids (TTHM and HAA5) are formed as a by-product of drinking water chlorination. This chemical reaction occurs when chlorine combines with naturally occurring organic matter in water. Compliance is based on running annual average.

All other regulated drinking water contaminants were below detection levels.

Secondary Contaminants (You are not required to list detects for secondary contaminants, but this information, particularly sodium levels, might be useful to your customers. The decision to supply this information in your CCR is up to you.)

| | | |
|-----------|-----------|-----------|
| SODIUM | 16 ppm | 5/10/2021 |
| CHLORIDE | 17 ppm | 5/10/2021 |
| IRON | 0.091 ppm | 5/10/2021 |
| MAGNESIUM | 0.95 ppm | 5/10/2021 |
| MANGANESE | 0.023 ppm | 5/10/2021 |

Health Information

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production and can also come from gas stations, urban runoff, and septic systems.

Radioactive Contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791) or at the following link:

<https://www.epa.gov/ccr/forms/contact-us-about-consumer-confidence-reports>

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Great Salt Bay Sanitary District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at the following link:

<http://www.epa.gov/safewater/lead>

Violations

| Violation Period | Violation Type |
|-----------------------|--|
| 7/1/2021 - 9/30/2021 | 27 Violation - MONITORING, ROUTINE (DBP), MAJOR TTHM/HAAC-STAGE 2 DIST SYS |
| 4/21/2021 - 8/16/2021 | 57 Violation - OCCT/SOWT RECOMMENDATION/STUDY (LCR) LEAD & COPPER RULE |

We are required to monitor our drinking water for specific contaminants on a regular basis. Results of regular monitoring indicate whether or not our drinking water meets health standards. During 2021, we did test for, all necessary tests for Total Trihalomethanes (TTHM) and/or Haloacetic Acids (HAA5), Because of a laboratory email issue our results were not reported to the DWP on time (indicated as a Reporting violation above).

Reporting Violation: In 2021, we were required to submit/update a corrosion control treatment plan, due to an exceedance of a lead or copper action level. A corrosion control treatment plan is required to help our system understand our water chemistry and provide treatment to reduce the corrosivity of our water. We conducted a treatment plan update but due to unforeseen issues the plan took longer than the allowed timeframe

| | |
|-----------------------|---|
| 7/1/2021 - 12/31/2021 | SE Violation - STATE EXCEEDANCE LEAD SUMMARY DIST SYS |
|-----------------------|---|

Lead & Copper Action Level Exceedance: In 2021, routine sampling detected (lead/copper) in excess of the maximum level allowed. 3 out of 44 sites sampled, exceeded the action level for (lead/copper). Drinking water regulations require that samples are taken from homes with a high-risk potential for lead/copper in the plumbing. The following were action steps we were required to take and the dates those actions were completed: Distribute public lead/copper education material to all

residents (Done on 3/14/22); Submit a corrosion control plan to the State Drinking Water Program (Done on 3/15/22). Our plan we submitted to reduce the corrosivity of the water (or reduce lead/copper levels) involves: Changing from Sodium Silicate type "D" to Sodium Silicate type "N" which will enable us to optimize Soda Ash addition to raise the PH and Alkalinity_We have to fully implement/complete our plan by June of 2022. Lead/copper sampling will resume in M a y o f 2 0 2 2 . Results of subsequent future lead/copper testing will be made available to all residents. Lead Health Effects: Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure. Copper Health Effects: Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short time could experience gastrointestinal distress, or suffer liver or kidney damage. People with Wilson's Disease should consult their doctor.

Waiver Information (to be included in the CCR for systems that were granted a waiver)

In 2020, our system was granted a 'Synthetic Organics Waiver.' This is a three-year exemption from the monitoring/reporting requirements for the following industrial chemical(s): TOXAPHENE/CHLORDANE/PCB, HERBICIDES, CARBAMATE PESTICIDES, SEMIVOLATILE ORGANICS. This waiver was granted due to the absence of these potential sources of contamination within a half mile radius of the water source(s).